PORTABLE APPLIANCE TESTING REPORT

KELD Ampworks

REPORT NO.:	Sample
DATE:	10/10/2017

www.ampworks.co.uk

ID NO.	APPLIANCE DESCRIPTION	APPLIANCE LOCATION	CLASS	VISUAL INSPECT	TEST		Polarity	Leakage mA	Functional Check	DATE OF NEXT TEST	PASS or FAIL	COMMENTS
					EARTH Ohms	INSULATION Mohms						
PAT17OCT2001	Fender MV Silverface	N/A	1	Pass	0.08	20	n/a	0.07	Pass	10/10/18	Pass	
PAT17OCT2002	1kW PA amp	N/A	1	Pass	0.09	20	n/a	0.09	Pass	10/10/18	Pass	
PAT17OCT2003	Pedal PSU	N/A	1	Pass	0.08	20	n/a	0.05	Pass	10/10/18	Pass	
PAT17OCT2004	Rack EQ	N/A	1	Pass	0.08	20	n/a	0.07	Pass	10/10/18	Pass	
PAT17OCT2005	Lights 4 bar	N/A	1	Pass	0.06	20	n/a	0.07	Pass	10/10/18	Pass	
PAT17OCT2006	Fender MV Silverface	N/A	1	Pass	0.08	20	n/a	0.05	Pass	10/10/18	Pass	

TOTAL APPLIANCES:

TEST ENGINEER SIGNATURE: Rowan Diskin

TEST ENGINEER NAME: Rowan Diskin